



PIPE DEPTH			
DIMENSION	A	B	C
1/2" - 2 1/2"	18"	12"	6"
3" - 4"	24"	X	6"
6"	36"	X	6"

PIPE TYPE	
SIZE	TYPE
1/2" - 2"	SCHEDULE 40
2 1/2" - 3"	CLASS 315
4" - 6"	CLASS 200

NOTE:

1. ALL PIPE UNDER PAVING, SHALL BE INSTALLED IN A PURPLE PVC CL 200 SLEEVE TWICE THE DIAMETER OF THE CARRIER PIPE AND LOCATED AT A DEPTH OF 36" TO TOP OF SLEEVE.

REVISIONS						EASTERN MUNICIPAL WATER DISTRICT	
DATE	BY	MARK	DESCRIPTION	APPR.	DATE	PIPE TRENCH	A-004
						APPROVED: _____	DATE: _____
						LAST UPDATED: 06-01-2021	SCALE: 1" = 1'-0"