



- ① FINISHED GRADE IN TURF AREAS
- ② PLASTIC PURPLE RECTANGULAR VALVE BOX WITH BOLT DOWN COVER, USE STAINLESS BOLT, NUT, AND WASHER. BOX TO BE PLACED AT RIGHT ANGLE TO HARDSCAPE EDGE. HEAT BRAND "STUB NO." ONTO LID.
- ③ LOCKING BRASS BALL VALVE. BALL VALVE SHALL BE IN A CLOSED POSITION AND CLOKED.
- ④ FINISHED GRADE IN SHRUB AREAS
- ⑤ RECYCLED IRRIGATION WATER PRESSURE SUPPLY LINE.
- ⑥ THREADED BRASS NIPPLE, LINE SIZE, 3" MIN. LENGTH.
- ⑦ BRICK SUPPORTS
- ⑧ BRASS UNION
- ⑨ THREADED BRASS NIPPLE (LENGTH AS REQUIRED)
- ⑩ LANDSCAPE FABRIC
- ⑪ 3/4" ROCK, FILL BOX UP TO BOTTOM OF MAINLINE AND BALL VALVE.
- ⑫ RECYCLED ID. WATER ADVISORY WARNING TAG AND TAG LABELED "RW IRRIGATION STUB OUT."
- ⑬ THREADED BRASS END CAP SECURELY TIGHTENED
- ⑭ PULL BOX FOR FUTURE REMOTE CONTROL VALVE WIRES CONNECTED TO MASTER CONTROLLER. CAP WITH WATERPROOF WIRE CONNECTIONS
- ⑮ FUTURE MAINLINE PER EMWD APPROVAL

NOTES:

1. FOR RECYCLED WATER, VALVE BOXES AND ALL PIPING SHALL BE PURPLE
2. BOX TO BE INSTALLED AT RIGHT ANGLE TO HARDSCAPE EDGE AS TO ALLOW FOR PROPER OPERATION OF BALL VALVE INSTALL; INSTALL VALVE OFF-CENTER IN BOX.
3. INSTALL VALVE BOX EXTENSIONS AS REQUIRED TO ACHIEVE PROPER VALVE INSTALLATION AT MAIN LINE DEPTH.
4. EMWD REQUIREMENTS FOR FUTURE PHASE: IRRIGATION PLAN REVIEW, PRE CONSTRUCTION MEETING, INSPECTION AND TESTING SHALL BE COMPLETED PRIOR TO ANY RECYCLED WATER CONNECTION.

REVISIONS						EASTERN MUNICIPAL WATER DISTRICT	
DATE	BY	MARK	DESCRIPTION	APPR.	DATE		
						RECYCLED WATER STUB OUT	A-006
						APPROVED: <u>EXAMPLE</u>	DATE: _____
						DATE PREPARED: 10-22-10	N.T.S.