



- NOTES: 1. INSTALL DIELECTRIC UNION BETWEEN DISSIMILAR METALS. 1 2
 FOR MFR, MATERIALS, MODEL SEE SPEC, SECTION E15430.
 2. INSULATE EMERGENCY SHOWER & EYEWASH UNITS LOCATED OUTSIDE PER SPEC.
 3. SUPPORT PIPING FROM ADJACENT WALL OR PROVIDE APPROVED FREE-STANDING PIPE SUPPORTS.

REVISIONS	INITIAL	APP'D	DATE	NO SCALE	INITIAL	DATE
A REVISED	RE	<i>[Signature]</i>	6/13/07	DESIGNED		
B REVISED	RE	<i>[Signature]</i>	4/28/10	DRAWN	R.E.	5/2/2007
				CHECKED		
				RECOMMENDED		
				APPROVED	<i>[Signature]</i>	
				DATE	04/28/2010	

EASTERN MUNICIPAL WATER DISTRICT
 RIVERSIDE COUNTY . CALIFORNIA

EMERGENCY SHOWER & EYEWASH

A-540