



FLEXIBLE COUPLING
(NON-PRESSURE)

NOTE:

NO CONNECTION ALLOWABLE AT BELL END OF VCP. CUT BELL END OFF VCP PRIOR TO MAKING CONNECTION.

REVISIONS						APPROVALS			EASTERN MUNICIPAL WATER DISTRICT STANDARD DRAWING	
NO.	DATE	INITIAL	DESCRIPTION	APP'D	DATE		INITIAL	DATE	CONNECTING DISSIMILAR SEWER PIPES	
						DESIGN	AGA	4/23/19		
						CONSTRUCTION				
						INSPECTION	BAM	4/23/19		
						OPERATIONS	MMM	6/4/19		
						SUBMITTED	AGA	4/23/19		
REFERENCES: SUPERCEDES SA-79				SCALE: NONE		RECOMMENDED <u>Corey Wallace</u> <u>6/5/19</u> <small>DIRECTOR OF ENGINEERING DATE</small>			APPROVED <u>Joe Mouawad</u> <u>6/11/19</u> <small>ASSISTANT GENERAL MANAGER DATE</small>	
FILE I.D.: \kauai\eng\std dwgs\SB-182.dgn				DRAWN BY: GS					SB-182	