

**UPDATE LOG FOR SECTION 11005**

Date	Item(s) Changed	Page #
5/13/21	<p>1.07 SUBMITTALS Refer to Section F Labor and Construction, F-<del>30</del> 29, Paragraph D. "Submittals" and to specific Divisions and Sections for additional submittal requirements.</p> <p>3.11 EARTHQUAKE DESIGN AND RESTRAINT <u>Minimum Earthquake Forces.</u> The minimum earthquake forces shall be those prescribed for Essential Facilities by <b>the latest edition of the Uniform</b> California Building Code and applicable supplements as published by the <del>International Conference of Building Officials, 5360 South Workman Mill Road, Whittier, California 90601</del> California Building Standards Commission or the International Code Council, <del>or as unless otherwise specified elsewhere in the "Soil Investigation Report", Contract Documents whichever is greater.</del></p> <p>Contractor shall submit shop drawings, details and data herein <del>before</del> <b>as</b> specified in Section F General Conditions, F-<del>30</del> 29, Paragraph D. "Submittals."</p>	<p style="text-align: center;">2</p> <p style="text-align: center;">17</p>
10/05/07	<p>Removed Exhibit A – Maintenance Bond and revised the following to read as follows:</p> <p>3.10 Pumps</p> <p>F. <u>MAINTENANCE BOND FOR PUMPING EQUIPMENT.</u> The contractor <b>or his supplier</b> shall provide a maintenance bond <del>(See Exhibit A)</del> <b>(See EMWD Standard form C-14 or C-14.1)</b> from a bonding company acceptable to the District equal to 100% of the pumping equipment value (including motors, pumps and pump assemblies) for a two (2) year term starting when the District has accepted the contracted work. Equipment and/or components failing within this period due to deficiency in design, workmanship or material shall be removed, replaced, and reinstalled at no cost to the District, and said replacement shall be guaranteed for two years continuous service. The maintenance bond shall be submitted to the District prior to the performance test of the pump(s).</p>	<p style="text-align: center;">16</p>

**Change Legend:**

**Added**  
~~Strike-out~~

**Document is prepped for double-sided printing**

