

UPDATE LOG FOR SECTION 15351

Date	Item(s) Changed	Page #
10/05/07	<p>Removed Exhibit A – Maintenance Bond and revised the following to read as follows:</p> <p>3.12 <u>MAINTENANCE BOND FOR PUMPING EQUIPMENT</u></p> <p>For District administered contracts, the Contractor or his Supplier shall provide a maintenance bond (see Exhibit A) (see EMWD Standard form C-14 or C-14.1) from a bonding company acceptable to the District equal to 100 percent of the pumping equipment value (including motors, pumps, and pump assemblies) for a two (2) year term starting when the District has accepted the contracted work. Equipment and/or components failing within this period due to deficiency in design, workmanship, or materials shall be removed, replaced, and reinstalled at no cost to the District, and said replacement shall be guaranteed for two years continuous service from the date of replacement. The maintenance bond shall be submitted to the District prior to the performance test of the pump(s).</p> <p>For contracts not administered by the District (e.g. contracts administered by Developer, or Developer's Engineer), the Developer shall provide the above referenced maintenance bond to the District.</p>	10

Change Legend:

Added

~~Strike-out~~

Document is prepped for double-sided printing