


NOTES

1. CONTRACTOR SHALL RAISE SLIP CAN TO GRADE AFTER STREET IS PAVED, WHERE PAVING IS PROPOSED.
2. IN UNPAVED AREAS, CONTRACTOR SHALL LEAVE CAP AND SLIP CAN 18" BELOW FINISH GRADE. (I.E. GRADED SHOULDERS).
3. IN NEW SUBDIVISIONS WHERE IT IS SPECIFICALLY GIVEN TO OTHERS (AS SPECIFIED) TO RAISE CAP AND CAN TO FINISH GRADE UPON COMPLETION OF PAVING. WATER CONTRACTOR SHALL FURNISH STEM EXTENSION, SLIP CAN AND CAP TO DISTRICT STORAGE YARD, AND LEAVE VALVE CANS PROPERLY COVERED WITH 2"x8"x8" REDWOOD PLATE.
4. SET TOP OF TRAFFIC COVER SUFFICIENTLY BELOW ROUGH GRADED SUB-GRADE TO AVOID DAMAGE DURING FINE GRADING AND SCARIFYING OPERATION.
5. DOMESTIC WATER INSTALLATION: VALVE CAP TO BE PAINTED SAFETY PRECAUTION BLUE ENAMEL AND PRIMER, AS APPROVED, AND MARKED "WATER". RECYCLED WATER INSTALLATIONS: VALVE CAP LID TO BE PAINTED PURPLE AND MARKED "RECYCLED".

Spec No. 1307P - Addendum No. 1

REVISIONS					APPROVALS			EASTERN MUNICIPAL WATER DISTRICT STANDARD DRAWING	
NO.	DATE	INITIAL	DESCRIPTION	APP'D	DATE	DESIGN	INITIAL	DATE	VALVE CAP & RISER DETAIL
						CONSTRUCTION	<i>MJ</i>	11/10/14	
						INSPECTION	<i>CD</i>	11/3/14	
						OPERATIONS	<i>KG</i>	10/30/14	
						SUBMITTED	<i>AGA</i>	10/30/14	
△	XX/XX/XX	GS	RESTORED ORIGINAL TRIANGULAR CAP	<i>XXX</i>	xx/xx/xx				
REFERENCES: SUPERCEDES A-492 & PA-2				SCALE: NONE				EASTERN MUNICIPAL WATER DISTRICT VALVE CAP & RISER DETAIL	
FILE I.D.: \kawaii\eng\std dwgs\B-668.dgn				DRAWN BY: GS					
								B-668	

