



EASTERN MUNICIPAL WATER DISTRICT
August 21, 2019

SPECIFICATION NO. 1376W
WELL 59 WELLHEAD TREATMENT FACILITY

LETTER OF CLARIFICATION No. 001

This Letter of Clarification to the specifications is for the purpose of clarifying certain information to the construction drawings and project specifications as follows:

The GAC vessel layout proposed by Loprest does not comply with specification requirements for the vessel underdrain system. This vessel is not considered an equal and will not be considered for bid for this project.

Eastern Municipal Water District

A handwritten signature in blue ink, appearing to read 'Joe Mouawad', is written over the printed name.

FOR

Joe Mouawad, P.E.
Assistant General Manager,
Planning, Engineering & Construction

PE: DC
PM: [Signature]
DFE: BXM
DE: BXM

DC:bp