



May 7, 2020

ADDENDUM NO. 001 TO SPECIFICATION NO. 1397W
Vista Tank Interior Recoating

This addendum to the specifications is for the purpose of adding, clarifying, or deleting certain information to the construction drawings and project specifications as follows:

NON-MANDATORY PRE BID WALK THROUGH

A non-mandatory pre-bid walk-through meeting was conducted on April 29, 2020 at 9:00 a.m.

NOTE: Refer to EMWDs website to obtain the Pre Bid Walk-Through Sign-In Sheet.

QUESTIONS & ANSWERS

Liberty Maintenance, Inc.

Q1. Paragraph SC-54 states that the coating contractor must be certified by the National Association of Corrosion Engineers. What is the exact certification required for the company?

Are you aware that NACE and SSPC are in the process of Merging?

A1. The District will accept any NACE certification. The District is aware that NACE and SSPC are in the process of merging.

J. Colon Coatings, Inc.

Q1. Per Special Conditions SC-62 & Appendix H is the Asbestos removal part of the scope of work?

We do not see that the asbestos will be disturbed during construction. If so will the Caulking need to be replaced?


A1. If the contractor does not disturb the asbestos caulking during construction, the caulking will not need to be removed. However, if the contractor disturbs the caulking during construction, the contractor shall handle and dispose of the asbestos caulk per the specifications.

Hulsey Contracting

Q1. We have this piece of machinery "EcoQuip Vapor Abrasive Blaster dual line" we are using and it is not included in the spec. We would like to use the process for the tanks just want to get it approved.

A1. The District will not allow the use of "EcoQuip Vapor Abrasive Blaster dual line."

Eastern Municipal Water District



Paul D. Jones II, P.E.
General Manager

PE: SW
PM: SW
DFE: BAN
DE: ST

PDJ:JA:ae