



5/24/2021

ADDENDUM NO. 1 TO SPECIFICATION NO. 1417W
Sherman Road Brackish Water Transmission Pipeline

This addendum to the specifications is for the purpose of adding, clarifying, or deleting certain information to the construction drawings and project specifications as follows:

SECTION P – CONTRACT DRAWINGS

REPLACE the following Contract drawings in their entirety, attached hereto (changes are noted as delta 1):

D-59948	Title Sheet and Sheet Index
D-59950	Notes
D-59951	Key Map
D-59952	Plan and Profile Sta. 9+98.69 to 19+00
D-59953	Plan and Profile Sta. 19+00 to 28+00
D-59957	Plan and Profile Sta. 54+00 to 63+67.18

APPENDICES

REPLACE the following appendices in their entirety, attached hereto:

Appendix E Work Restrictions, Sequence of Work, and Control Strategy

NON-MANDATORY PRE BID WALK THROUGH

A non-mandatory pre-bid walk-through meeting was conducted on May 12, 2021 at 9:00 a.m.


NOTE: Refer to EMWDs website to obtain the Pre Bid Walk-Through Sign-In Sheet.

QUESTIONS & ANSWERS

CCL Contracting, Inc.

- Q1. Can equipment be left within the r/w during non-working hours with proper traffic barriers in place?
- A1. If private property is used for storage of materials and equipment, Contractor shall obtain written permission from affected property owners. Similarly, if public property and/or public right-of-way is used for storage of materials and equipment, Contractor shall obtain written permission from affected agencies. Refer to Special Conditions SC-30 for additional information.
- Q2. Does the traffic control plan have to be signed by a RCE?
- A2. Traffic control plan shall be prepared by a professional engineer licensed in the State of California.
- Q3. Will Sound Barrier Walls be required and if so can you provide locations / limits?
- A3. Contractor shall select and implement appropriate means of effecting compliance with the noise control ordinances of the respective jurisdictions having authority (JHAs); this could include use of engine silencers, sound blankets or other available means of noise suppression (see Special Conditions SC-31). If noise control barrier walls are utilized, they shall be designed and installed by Contractor; length, height, and location of noise control barrier walls, if required, shall be adequate to assure proper acoustical performance.
- Q4. If Sound Barrier Walls are required can an allowance item be added to the bid schedule?
- A4. All cost associated with noise control shall be included in the bid and no additional compensation shall be made therefor.

Eastern Municipal Water District

FOR

Joe Mouawad, P.E.
General Manager

PE: CRC
PM: BAM
DFE: BAM
DE: S

JM:cc:ma:jrm

- ATTACHMENTS:
- Drawing D-59948
 - Drawing D-59950
 - Drawing D-59951
 - Drawing D-59952
 - Drawing D-59953
 - Drawing D-59957
 - Appendix E: Work Restrictions, Sequence of Work, and Control Strategy