

SECTION 15102S
VALVE SCHEDULE
Addendum No. 3

TAG NUMBER	SIZE (in)	LOCATION	Type of installation (1)	End Connection (2)	Actuator Type (3)	Extension Stem Type	Depth Below Grade, ft (4)	Valve Box	Extension Stems
VG-1111	16	Raw Water Bypass before Cartridge Filters	B	F	WN	Non-rising Stem	8	Yes	Yes
VG-2261	12	Finished Water Discharge to Fire Suppression System	B	F	WN	Non-rising Stem	6	Yes	Yes
VG-2262	6	Finished Water Discharge to Plant	B	F	WN	Non-rising Stem	6	Yes	Yes
VG-2266	3	Finished Water Discharge to Plant	B	F	WN	Non-rising Stem	6	Yes	Yes
VG-2265	12	Finished Water Discharge After Blow Off Assembly	B	F	WN	Non-rising Stem	8	Yes	Yes
VG-9101	12*	Brine Receiving Station Effluent	S	F	WN	Non-rising Stem	8.5	Yes	Yes
VG-9103	4*	Brine Receiving Station - Drain	S	F	WN	Non-rising Stem	9.5	Yes	Yes
VG-9102	8*	Brine Receiving Station	S	F	WN	Non-rising Stem	8.5	Yes	Yes

Notes:

Resilient Seated Gate Valves

Section 15102S - 2

* Valves furnished and installed in submerged applications within the Brine Receiving Station shall be fabricated with materials or coated to withstand the water quality as indicated in Low Pressure RO System section.

(1) Abbreviations for installation types are as follows:

- E Exterior Above Grade
- B Buried
- IB Inside Building Above Grade
- S Submerged

(2) Suffix letters define valve ends as follows:

- F Flanged
- W Wafer
- MJ Mechanical Joint

(3) Abbreviations for actuator types are as follows:

- WN Wrench Nut
- LVR Lever
- CW Chainwheel
- HW Handwheel
- M Motor Operated

(4) Valve Depth shall be field verified.

END OF SECTION