



CUBIC FT. OF CONCRETE						
PIPE SIZE	CLASS 150 TEST PRESS. 225 psi			CLASS 200 TEST PRESS. 300psi		
	45°	22.5°	11.25°	45°	22.5°	11.25°
	4	15	8	4	20	10
6	33	17	9	44	22	11
8	58	30	15	77	40	20
12	—	—	34	—	—	45

**NOTES:**

1. — INDICATES ANCHOR BLOCK MUST BE DESIGNED FOR EACH INDIVIDUAL CASE.

REVISIONS	SCALE	INITIAL	DATE
		NRZ	7/83
		B.R.H.	7/83
		NRZ	8/83

EASTERN MUNICIPAL WATER DISTRICT  
RIVERSIDE COUNTY, CALIFORNIA

STANDARD DRAWING  
ANCHOR BLOCK  
(VERTICAL BEND ONLY)

A-530