

RECOMMENDED.

NOTES:

- 1. CLASS "C" CONCRETE PAD TO BE POURED AGAINST UNDISTURBED TRENCH WALL AFTER PIPE IS INSTALLED & FLANGE CONNECTION IS MADE TO CI FITTING OR VALVE.
- 2. PAD SHALL BE POURED TO AVOID INTERFERENCE WITH CONNECTIONS OR SPECIAL FITTINGS.
- 3. VALVES 12" & SMALLER SHALL BE SUPORTED AS SHOWN HEREON. REFER TO DWGS B-255 & DWG B-279 FOR ADDITIONAL SUPPORTS FOR VALVES 14" & LARGER.
- 4. WHERE VALVES ARE CALLED OUT ON CONSTRUCTION DRAWINGS BOLT VALVES TO CI FITTINGS & THEN PROCEED WITH SUPPORT ASSEMBLY AS SHOWN.
- 5. RECYCLED WATER PIPELINE TO HAVE
 (3") THREE INCH WIDE LOCATOR TAPE
 PLACED ABOVE THE RECYCLED WATER
 PIPELINE STATING "CAUTION RECYCLED
 WATER" IN (2) TWO INCH HIGH LETTERS.
 THE COLOR OF THE TAPE SHALL BE
 PURPLE.

REVISIONS						APPROVALS		
NO.	DATE	INITIAL	DESCRIPTION	APP'D	DATE		INITIAL	DATE
						DESIGN	JVS	
						CONSTRUCTION	BKM	
						INSPECTION		
2	4/23/21	GS	UPDATED TITLE BLOCK, LOGO FONT AND ADDED NOTE 5	AGA	4/23/21	OPERATIONS	CAG	
\triangle	11/18/98	GR	REDRAWN W/CADD ON MYLAR	VJB	4/27/99	SUBMITTED	LAM	3/18/77
REFERENCES: SUPERCEDES A-422					IONE			•

FILE I.D.: \kauai\eng\std dwgs\B-563.dgn

DRAWN BY: MCA



DATE

DIRECTOR OF ENGINEERING

EASTERN MUNICIPAL WATER DISTRICT STANDARD DRAWING

STEEL PIPELINE PIPE PAD OR COUPLING FOR CAST IRON FITTINGS

APPROVED Doyle F. Boen

GENERAL MANAGER & CHIEF ENGINEER

3/18/77

B-563