

Notice of Determination

Appendix D

To:

[X] Office of Planning and Research
U.S. Mail: Street Address:
P.O. Box 3044 1400 Tenth St., Rm 113
Sacramento, CA 95812-3044 Sacramento, CA 95814

[X] County Clerk
County of: Riverside
Address: 2724 Gateway Drive
Riverside, CA 92507

From:

Public Agency: Eastern Municipal Water District
Address: P.O. Box 8300
Perris, CA 92572-8300
Contact: Joseph Broadhead
Phone: 951-928-3777 ext. 4545

Lead Agency (if different from above):
Address:
Contact:
Phone:

SUBJECT: Filing of Notice of Determination in compliance with Section 21108 or 21152 of the Public Resources Code.

State Clearinghouse Number (if submitted to State Clearinghouse): 2020030267

Project Title: Cactus Avenue Corridor Groundwater Wells Project

Project Applicant: Eastern Municipal Water District

Project Location (include county): Moreno Valley, Riverside County

Project Description:

The Cactus Avenue Corridor Groundwater Wells Project consists of development and operation of groundwater extraction, treatment, and distribution facilities in the Perris North Groundwater Management Zone. The Project includes construction and operation of extraction wells, raw water pipelines, a water treatment and blending facility, and treated water pipelines. Up to four extraction wells (each approximately 250 gpm) would be constructed in the North Sub-Area and up to two extraction wells (each approximately 650 gpm) would be constructed in the East Sub-Area. The treatment facility would be constructed and operated at a central location that would include granular

This is to advise that the Eastern Municipal Water District has approved the above (X) Lead Agency or () Responsible Agency

described project on May 20, 2020 and has made the following determinations regarding the above described project

- 1. The project () will (X) will not have a significant effect on the environment.
2. () An Environmental Impact Report was prepared for this project pursuant to the provisions of CEQA. (X) A Negative Declaration was prepared for this project pursuant to the provisions of CEQA.
3. Mitigation measures (X) were () were not made a condition of the approval of the project.
4. A mitigation reporting or monitoring plan (X) was () was not adopted for this project.
5. A statement of Overriding Considerations () was (X) was not adopted for this project.
6. Findings () were (X) were not made pursuant to the provisions of CEQA.

This is to certify that the final EIR with comments and responses and record of project approval, or the negative Declaration, is available to the General Public at:

Eastern Municipal Water District, 2270 Trumble Road, Perris, CA 92570

Signature (Public Agency): [Signature] Title: Principal Water Resources Specialist

Date: 5/21/20 Date Received for filing at OPR: