



**NOTES:**

1. USER MUST SUPPLY ALL FITTINGS, NIPPLES, VALVES AND APPROVED REDUCED PRESSURE PRINCIPLE BACKFLOW PREVENTION ASSEMBLY. ALL FITTINGS AND NIPPLES MUST BE BRASS. THE DISTRICT SHALL SUPPLY THE WATER METER.
2. BACKFLOW ASSEMBLY MUST BE TESTED BEFORE USE BY A CERTIFIED BACKFLOW ASSEMBLY TESTER APPROVED BY EMWD.
3. HYDRANT MUST BE FULLY OPENED DURING USE.
4. PROVIDE ADJUSTABLE PIPE SUPPORT AS REQUIRED BY DISTRICT'S REPRESENTATIVE.
5. PRESSURE REGULATOR, IF NEEDED SHALL BE INSTALLED DOWNSTREAM OF BACKFLOW PREVENTER ASSEMBLY, USE COPPER PIPE.

**REVISIONS**

DATE	BY	MARK	DESCRIPTION	APPR.	DATE
<b>EASTERN MUNICIPAL WATER DISTRICT</b>					
TEMPORARY POTABLE WATER CONSTRUCTION 'T'-METER <sup>1</sup>				A-001	
APPROVED: _____			DATE: _____		
DATE PREPARED: 10-22-10					SCALE: 1" = 1'-0"