



NOTES:

1. SQUARE POST SHALL BE PERFORATED STEEL TUBE POSTS WITH TWO PIECE ANCHOR AND 'TELESPAR' SLEEVE. THE ANCHOR AND SLEEVE ASSEMBLY SHALL CONSIST OF A 2 1/2" SQUARE BY (30" THROUGH SIDEWALK) OR (36" THROUGH SOIL). ANCHOR WITH A 2 1/4" BY 18" SLEEVE.
2. THE NUMBER OF SIGNS, THEIR LOCATIONS, AND HEIGHTS SHALL BE PER EMWD REQUIREMENTS AND AS DIRECTED BY THE DISTRICT REPRESENTATIVE. AT A MINIMUM SIGNS SHALL BE LOCATED AT ALL PROJECT ENTRIES AND AT EACH METER CONNECTION.
3. ANCHOR AND SLEEVE ASSEMBLIES SHALL BE DRIVEN SIMULTANEOUSLY UNTIL 4" REMAINS ABOVE GROUND LEVEL. INSTALL THE 2" GALVANIZED SQUARE SIGN POST MINIMUM 6" INTO THE ANCHOR ASSEMBLY AND SECURE IN PLACE WITH TWO 3/8" DRIVE RIVETS AS SHOWN. THE RIVETS SHALL BE INSTALLED ON THE SIDE FACING TRAFFIC FLOW AND THE SIDE OF APPROACHING TRAFFIC AS SHOWN.
4. ANCHOR ASSEMBLY SHALL NEVER BE SECURED IN CONCRETE FOOTING
5. ADVISORY SIGN CAN BE PURCHASED FROM EMWD AT (951) 928-3777 EXT. 4412

REVISIONS						EASTERN MUNICIPAL WATER DISTRICT	
DATE	BY	MARK	DESCRIPTION	APPR.	DATE		
10/7/19	GS	⚠	ADDED MINIMUM SIGN SIZE	AGA	10/7/19	RECYCLED WATER IRRIGATION ADVISORY SIGN	A-008
						APPROVED: _____	DATE: _____
						DATE PREPARED: 10-22-10	SCALE: 1" = 1'-0"