



NOTES:

1. ALL MATERIALS SHALL CONFORM TO THE UNIFORM PLUMBING CODE AND AWWA STARDARDS.
2. THIS ASSEMBLY IS MEANT TO SEPARATE/ISOLATE THE BUILDING SUPPLIED WITH POTABLE WATER DURING CROSS CONNECTION SHUT DOWN TESTING.
3. SIZING OF THE CROSS CONNECTION ISOLATION VALVE ASSEMBLY WILL BE DETERMINED BY THE CIVIL ENGINEER/PLUMBER.

REVISIONS						EASTERN MUNICIPAL WATER DISTRICT	
DATE	BY	MARK	DESCRIPTION	APPR.	DATE		
						BUILDING CROSS CONNECTION ISOLATION VALVE	
						A-012	
						APPROVED: <u>EXAMPLE</u> DATE: _____	
						DATE PREPARED: 02-26-2020	SCALE: NONE