



NOTES:

1. ALL MATERIALS SHALL CONFORM TO THE UNIFORM PLUMBING CODE AND AWWA STARDARDS.
2. THIS ASSEMBLY IS MEANT TO SEPARATE/ISOLATE THE BUILDING SUPPLIED WITH POTABLE WATER DURING CROSS CONNECTION SHUT DOWN TESTING.
3. SIZING OF THE CROSS CONNECTION ISOLATION VALVE ASSEMBLY WILL BE DETERMINED BY THE CIVIL ENGINEER/PLUMBER.

REVISIONS						EASTERN MUNICIPAL WATER DISTRICT		
DATE	BY	MARK	DESCRIPTION	APPR.	DATE			
3-10-22	HNC	①	REVISED DETAIL TITLE	GS	3-10-22	CROSS CONNECTION TEST ISOLATION VALVE ① A-012		
						APPROVED: <u>EXAMPLE</u> DATE: _____		
						DATE PREPARED: 02-26-2020		SCALE: NONE