



PLAN VIEW
V.C.P. OR A.C.P.

NOTES FOR V.C.P. OR A.C.P. :

1. NO CONNECTION ALLOWABLE AT BELL END OF V.C.P. OR A.C.P.; CUT BELL END OFF PIPE PRIOR TO MAKING CONNECTION.
2. SEWER REPAIR COUPLING SHALL BE REPAIR COUPLINGS, OR APPROVED EQUAL, RING AS MANUFACTURED BY MISSION CLAY PRODUCTS, OR ASTM 5 594 5 5.1.2.3. IN CONFORMANCE WITH THE REQUIREMENTS OF ASTM 5 594 5 5.1.2.3. THE COMPRESSION BANDS AND CLIPS SHALL BE FABRICATED FROM STAINLESS STEEL A151 TYPE 316, AND THE BOLTS & NUTS FROM STAINLESS STEEL A151 TYPE 305, AND THE SHEAR RING FROM STAINLESS STEEL A151 TYPE 304.

REVISIONS		REFERENCES		SCALE		DATE	
NO.	DATE	INITIAL	DESCRIPTION	DESIGNED	NONE	DATE	
1	10-27-70	H.S.	GENERAL REVISIONS	L.A.M.		9-10-70	
2	2-16-73	M.C.M.	REV. 50 TO SAY "PLAN VIEW"	H.S.			
3	4-10-79	SBJ	Added Plastic Pipe				
4	2-2-83	CFW	REVISED DISTANCE BETWEEN FLEX ZPLG. AND CONC. ENCASEMENT				

APPROVALS		OPERATIONS	
DESIGN	CONSTRUCTION	DESIGN	OPERATIONS
<i>[Signature]</i>	<i>[Signature]</i>	<i>[Signature]</i>	<i>[Signature]</i>

EASTERN MUNICIPAL WATER DISTRICT RIVERSIDE COUNTY, CALIFORNIA	
STANDARD DRAWING SEWER CONNECTION AT CONC. ENCASEMENT V.C.P. A.C.P. GRAVITY SEWER & PLASTIC GRAVITY SEWER	
APPROVED	GENERAL MANAGER & CHIEF ENGINEER
	5B-63